













# Planning Payload Philosophy

- The planning payload is selected to demonstrate that the mission is scientifically and technically feasible.
  - Science requirements and measurements can be achieved
  - Payload resources can be accommodated by the spacecraft
  - Payload development risks are manageable
  - Payload costs are consistent with the \$2.1B mission cap
- The planning payload meets the measurement requirements and the resource constraints within the current cost cap.
  - Mass is currently not a driving concern
  - Power is currently not a driving concern (assuming 5 MMRTGs)
  - Cost is the primary concern and limiting factor for payload selection
- The planning payload is one means of meeting the science requirements defined by the Science Definition Team.
  - Alternative instruments and measurement techniques may be used to met the same requirements











# Planning Payload Implementation

- Instruments are assumed to be new designs for Europa in order to meet the radiation challenges for electronics and materials.
  - Radiation hardened application specific integrated circuits (ASICs)
     will replace field programmable gate arrays (FPGAs)
  - Radiation hardened mixed-signal ASICs will be a key instrument technology
  - The number of ASICs in each instrument is a parameter used in estimating payload cost
- Detectors are assumed to be new designs when estimating payload cost.
  - Radiation effects on existing detectors are under evaluation as an "existence proof" of technical feasibility











# Planning Payload Implementation

- Instrument electronics are located remotely in a shared electronics enclosure(s) for increased radiation shielding.
  - Minimal electronics are assumed in the instrument optical assembly, sensor head, etc.
  - A Common 6U compact PCI (cPCI) form-factor is assumed
  - This approach has been assumed when estimating payload mass
- A standardized interface is assumed for all instruments to minimize risk and development cost.
  - Availability of commercial intellectual property (IP) will simplify development of radiation hardened ASICs
  - Instrument bandwidth points to SpaceWire as the standard interface
- Data compression is performed within the instrument.
  - Limited solid-state recorder size points to compression prior to recording













# Planning Payload

•	Camera Package	7.5 kg	11.7 watts
	<ul> <li>Wide angle camera + medium angle camera</li> </ul>		
•	Spectrographic Imager	11.0 kg	15.0 watts
	<ul> <li>Near-IR imaging spectrograph</li> </ul>	_	
•	Laser Altimeter	7.1 kg	15.1 watts
	<ul> <li>Time-of-flight ranging</li> </ul>	_	
•	Magnetometer and Plasma Instrument	11.7 kg	14.0 watts
	<ul> <li>Dual magnetometers</li> </ul>		
	<ul> <li>Low energy plasma sensor</li> </ul>		
•	Ice Penetrating Radar	36.0 kg	45.0 watts
	<ul> <li>Dual frequency</li> </ul>		

NOTE: all mass and power figures are current best estimate (CBE)

 Additional instruments to augment the core payload have been identified and prioritized. A listing is included at the end of this presentation



















# Camera Package

## **Primary science investigations**

- Global stereo topography and surface color characterization
- Correlation of surface features to geological processes
- Characterize radiation effects on the surface
- Local surface characterization at higher resolution

## Measurement requirements - Wide Angle Camera

Spectral Range visible

**Spectral Bands** 3 color plus panchromatic **Spatial Resolution** 100 m (IFOV = 1 mrad)Image Width 1024 pixels (58 degrees)

Signal to Noise ≥ 100

#### Measurement requirements - Medium Angle Camera

Spectral Range visible

10 m (IFOV = 0.1 mrad)Spatial Resolution Image Width 2048 pixels (11 degrees)


Signal to Noise ≥ 100

# **Configuration for Planning Payload**

- Two telescopes, two detectors (CCD, pCCD or CMOS)
- Pushbroom operation; fixed color filters for WAC
- Passive cooling
- Fixed nadir pointing
- Electronics (6U cPCI) 1 WAC power/interface

1 MAC power/interface

# Similar heritage instruments



## **Resource requirements**

Mass 7.5 kg(CBE) 11.7 watts Power (CBE)

- WAC global color mapping
  - 3 colors plus panchromatic, 12 bits
  - Cross-track overlap for stereo
  - Nominal 213 Kbps
- MAC Targeted observations
  - Panchromatic, 12 bits/pixel
  - Nominal 1.07 Mbps (target bursts)

















# Spectrographic Imager

## Primary science investigations

- Characterization of surface composition
- Relate compositions to geological processes
- Characterize radiation effects on the surface
- Characterize exogenic materials

#### Measurement requirements

Spectral Range ~1.2 to ~4.8 μm

Spectral Resolution
 10 nm

Spatial Resolution
 Image Width
 100 m (IFOV = 1 mrad)
 ~350 pixels (20 degrees)

Signal to Noise ≥ 100

## Configuration for Planning Payload

- Single grating spectrometer
- Single HgCdTe detector
- Passive cooling
- Fixed nadir pointing
- Pixel processing options spectral binning / editing

spatial binning / editing


Electronics (6U cPCI)1 power supply


1 pixel processor/interface


## Resource requirements

MassPower11 kg (CBE)to watts (CBE)

# Similar heritage instruments







- Global mapping
  - Spectral and special binning options
  - · Spectral and spatial editing options
  - Nominal 100 Kbps
- Targeted observations
  - 350 cross-track pixels, 408 channels
  - 12 bits per pixel, 13 frames/second
  - Nominal 9 Mbps (target bursts)

















# Laser Altimeter

# Primary science investigations

- Amplitude and phase of gravitational tides
- Surface motion over the tidal cycle
- Determine Europa's dynamical rotation state
- Formation characterization of 3-D landforms

## Measurement requirements

Vertical AccuracyHorizontal Spacing50 meters

Spot Size50 meters (50 mrad)

Pulse Rate26 Hz


# Configuration for Planning Payload


- 1.064 µm Nd-YAG laser with single spot
- Reflective receiver telescope
- APD detector
- Fixed nadir pointing
- Radiation hardened time-of-flight ASICs
- Electronics (6U cPCI)1 laser power supply1 time-of-flight/interface

#### Resource requirements

Mass
 Power
 7.1 kg (CBE)
 15.1 watts (CBE)

# Similar heritage instruments





- Continuous operation
  - 26 Hz pulse repetition rate
  - ~ 2.5 kbps

















# Magnetometer and Plasma Instrument

# Primary science investigations

- Determine the induction response from the ocean
- Investigate the core, mantle, and rock-ocean interface
- Characterize the global radiation environment
- Flux and composition of plasma ions impacting Europa

## Measurement requirements - Mag

Dynamic Range 3000 nT
Sensitivity 0.1 nT
Sampling Resolution 0.01 nT

Max Sample Rate
 32 vectors/second

## Measurement requirements – Plasma

Energy Range10 eV to 10 KeV

 $\begin{array}{lll} - & \text{Angular resolution} & \quad 15 \text{ deg} \\ - & \Delta \text{E} \ / \ \text{E} & \quad 0.15 \end{array}$ 

# Configuration for Planning Payload


- Dual 3-axis fluxgate Magnetometer probes
- 10 meter spacecraft supplied boom
- Single body-mounted top-hat plasma analyzer
- Radiation hardened time-of-flight and energy ASICs
- Electronics (6U cPCI) 1 Mag

2 Plasma

#### Resource requirements

MassPower11.7 kg (CBE)14.0 watts (CBE)

Similar heritage instruments



Deep Space 1 PEPE

- Continuous operation
  - 32 Hz Mag sampling rate on orbit
  - 1 Hz Mag sampling rate during tour
  - 8 kbps

















# Ice Penetrating Radar

## Primary science investigations

- Search for an ice-ocean interface
- Characterize distribution of any shallow subsurface water
- Correlation of surface features to geological processes
- Characterize regional and global heat flow variations

#### Measurement requirements

- 10 m vertical resolution for depths from 100 m to 3 km
- 100 m vertical resolution for depths from 1 km to 30 km
- 50 km profile spacing over 80% of the surface

## Configuration for Planning Payload


- Dual-frequency sounder
  - 50 MHz with 10 MHz bandwidth
  - 5 MHz with 1 MHz bandwidth
- Deployed dipole antenna
- Range compression, pre-summing, Doppler filtering, data averaging, and resampling within the instrument
- Electronics (6U cPCI)
   6-8 boards

#### Resource requirements

_	Mass	36 kg	(CBE)
_	Power	45 watts	(CBE)

# Similar heritage instruments





MARSIS antenna prior to deployment

**SHARAD Electronics** 

- Shallow high resolution (50 MHz)
  - High spatial resolution (footprint and depth) above 3 km depth
  - ~300 Kbps
- Deep low frequency (5 MHz)
  - Lower spatial resolution for probing an ice/ocean boundary to 30 km depth
  - ~300 Kbps
- Raw data mode
  - Output unprocessed data
  - ~30 Mbps













# Prioritized Additions to the Planning Payload

- Narrow Angle Camera
  - IFOV = 0.01 mrad
- Augmented Spectrographic Imager
  - Spectral Range
     400 nm to 5 μm
  - Spatial Resolution
     25 meters
  - Dual grating spectrometer, dual detector
  - Articulation for target motion compensation
- UV Spectrograph (minimum configuration)
  - Spectral Range
     110 to 200 nm
  - Spectral Resolution 0.5 nm
  - Spatial Resolution 100 metersImage Width 64 pixels
- Thermal Imager
  - Spectral Range
     2-3 filters between 8 and 25 microns
  - Spatial Resolution
     250 500 meters
  - 320x240 pixel microbolometer array with TDI
- Energetic Particle Detector
- Ion and Neutral Mass Spectrometer
- Ultra-Stable Oscillator
- Dust Instrument